
8368069
R-502 HEADMASTER CONTROL VALVE REPLACEMENT KIT

Bushing, 1300041, must be used on condensers with a 3/8" OD discharge line. On condensers with a 1/2" OD discharge line, bushing, 1300041, can be discarded.



Manitowoc Ice, Inc.
2110 South 26th Street, P.O. Box 1720, Manitowoc, WI 54221-1720 USA
Telephone 920-682-0161, Fax - Sales: 920-683-7589, Service/Parts: 920-683-7585, Other: 920-683-7879
Web Site - www.manitowocice.com

8008633
Rev. 07/27/04